



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası, Kocaeli / TÜRKİYE
www.efectis.com

DECLARATION OF TEST RESULTS

No: ERA – 2300 – 0026

The related reaction to fire tests were carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 13 of February 2023. Classification of reaction to fire has been carried out in accordance the standard:

EN 13501-1:2018

“SPD 1000 – HS PIR Ins. Facade Panel – 50 mm”

Fire behaviour		Smoke production		Flaming droplets
B	-	s	1	, d 0

Flammability Classification*

Hardly inflammable

*Turkey's regulation on fire protection 2009, Appendix-2/Ç the table of flammability classification of construction materials in accordance with EN 13501-1

Placed on the market by: İZOCAM TİC. VE SAN. A.Ş.
Altayçeşme Mah. Çamlı Sok. Esas Ofispark No:21 Kat:4-5 Maltepe,
İstanbul / TÜRKİYE

Manufactured by: İZOCAM TİC. VE SAN. A.Ş.
GEBKİM Tesisleri Çerkeşli Köyü Yolu Üzeri Kocabayır Tepe Mevkii,
Kiplasma Cad., 41455 Dilovası, Kocaeli / TÜRKİYE

e-signed

Ali BAYRAKTAR
Laboratory Manager
31.08.2023

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: ERA-23-082.

